



ACCESSIBILITY PLAN
for
West Parry Sound Health Centre
&
Lakeland Long Term Care

2017

Status Update at March 5, 2020

Barriers to be Addressed in Future

Barrier	Objective	Means to Remove/Prevent	Timing	Responsibility	Status
Sidewalks need to be wider – not wide enough for a power chair; could also consider separate land for wheelchairs	To improve safety on site	\$500,000.00 to \$800,000.00 (cost barrier)	2020	Chief Financial Officer	Pending review
Cross walk on Ernie Eves Way for Pedestrians	Signal light installation to be considered		2020	Chief Financial Officer	Quotation to be requested
Nurse call system cords are too short	Need longer cords so patients can reach if sitting in a chair	Retractable cords to be trialed	2020	Clinical Manager	Reminder to Clinical Management Team
Signage / Symbol Assessment	Needs to be improved, (i.e. signs in elevators listing department locations); incorporation of international symbol system	Create new signage	2018	Communications Manager / Clinical Manager	Pending review
Seating in long corridor between Acute and Transitional Care: benches are too low; should be replaced with chairs with armrests	To improve safety on site	Acquire appropriate seating	2018	CFO / Clinical Manager	2018: arm chairs installed; 2020: seating review in many waiting areas being conducted; including proposed plan to purchase several “hip chairs”